

Approval Number 2312517
Test Report: J-00467580



12th December 2023

Guarniflon SpA
Via T Tasso 12
24060 Tagliuno Di Castelli
Calepio (BG)
Italy

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE)- MATERIAL ONLY.

5295

'PTFE G453'. Black coloured, extruded PTFE material. For use with water up to 85°C.

APPROVAL NUMBER: 2312517
APPROVAL HOLDER: GUARNIFLON SPA

The Scheme reserves the right to review approval.
Approval 2312517 is valid between December 2023 and December 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager